

July Maintenance Report for the Village of Elbow,2023

James Llewellyn

1. **Mowed and whipper snipped** around the village, parks, and cemetery.
2. **Cleared sand** hills on beach.
3. **Hydrant flush** and **maintenance checks** continue. Industrial area, King St., and Grey St complete.
4. **Hydrant** on Grey St. found to be **inoperable, broken casing** for gate valve stem on King St., as well as a **missing lid** for valve stem, and **miss sized lid** found for gate valve casing on Pfeffer and 749 rd.
5. **I've teamed up** with Warren from **Wolseley to repair Hydrant** on Grey St. and **add extensions to Hydrant** on Queen St. Aug.16th.
6. **Dock** has been **repaired** and **put in water** at Tuff's Bay.
7. **Removed sidewalk stops** at Harbor golf for sidewalk repair. I will put **car stops back this coming week**.
8. The **lot has been prepped** for contractor to install **new mailboxes**.
9. Purchased and **replaced broken passenger window** on work truck.
10. Helped with **set up for rodeo**: placement of **red bins**, set up **water line** from hydrant, **removed old freezer** and helped with **dust control**.
11. **Trimmed hedges** at cemetery and civic center.
12. Removed downed branches, dead trees, and yard waste from allies.
13. **Speed bumps placed** on Aaro Ave.
14. **Hvac filter changed** and system rest due to dust from landscaping project **at HGCC**.
15. **Doorstops installed** at HGCC.
16. **Watering cycle** continues for grass in ditch line **at HGCC**.
17. **Pruned dead branches** and **removed dead trees** from **PTP**.
18. **Fixed water lines** of multiple leaks at **PTP**
19. **Cypress** came out to HGCC to **rectify air filter size issue** and discussed best practices for maintenance.
20. **Downed St. light power line** on Minto and Bison. Sask. power came out and **removed hazard**. They will need to remove tree branches before light is repaired.
21. **Sprayed weeds** out at **lagoon**.
22. Prepped **lagoon gate repair**.
23. **Loose railway beam** on south side of village. CP has been notified and **service request sent**.
24. **Groomed Steets** with road boss around village.
25. **Play structure** at PTP **inspected** and no major defects found. **Weeds are growing** in play structure area.
26. **Truck route** sign and **children at play** signs prepped and **ready for installation**.
27. **Grader update**: Redhead had to order a **new block** for grader which is **coming from Ontario**. They were unable to repair old block.
28. **Regular maintenance** to equipment as needed.