



Sept 20, 2024

306-741-7718

Via Email: elbow@sasktel.net

Village of Elbow
Box 8
ELBOW SK S0H 1J0

Attention Waterworks Owner/Operator:

RE: Precautionary Drinking Water Advisory for *the Village of Elbow*: - Rescinded

The Water Security Agency (WSA) is satisfied with *two sets of* negative bacteriological sampling and adequate disinfection residuals and turbidity values from samples that have been collected from the water distribution system following power failure/pump failure causing the system depressurization. Therefore, effective immediately the WSA is rescinding the “**Precautionary Drinking Water Advisory**” for the residents and users of the *Village of Elbow* water supply.

For further information, please do not hesitate to contact the undersigned at 306-741-7718 or Scott.Klippenstein@wsask.ca.

Sincerely,

A handwritten signature in black ink, appearing to read "Scott Klippenstein".

Scott Klippenstein A. Sc. T.
Environment Officer
Water Security Agency

cc: Derrick Hoehn, Acting Manager, Compliance Promotion South, WSA (email)
Water Advisories, Water Security Agency
Saskatchewan Health Authority, Rosetown Office